CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

SunEvo Solar Co., Ltd.
No. 398 Ganquan Road, Hefei City
Anhui Province
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Valid from: 2022-03-18
Valid until: 2026-05-07

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC / EN 61215-1:2016;
	IEC / EN 61215-1-1:2016;
	IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018;
	IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018;
	IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.
Registered No.:	44 780 22 406749 - 057
Manufacturer:	see Annex 1
Test Report No.:	492011963.001
File No.:	PVP02108/22P

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2022-03-18

Please also pay attention to the information stated overleaf.

TÜV NORD CERT GmbH
Am TÜV 1
Fon +49 (0)201 825 5120
D-45307 Essen
Fax +49 (0)201 825 3209
www.tuev-nord-cert.de
prodcert@tuev-nord.de

Description of product(s):

Module types:	**PV Modules with 182mm Mono-crystalline Silicon Half-cut Solar Cells:** 156 cells: SE5-78H-xxxM (xxx = 560-605, in increment of 5) 144 cells: SE5-72H-xxxM (xxx = 520-555, in increment of 5) 132 cells: SE5-66H-xxxM (xxx = 475-510, in increment of 5) 120 cells: SE5-60H-xxxM (xxx = 430-465, in increment of 5) 108 cells: SE5-54H-xxxM (xxx = 390-415, in increment of 5) 96 cells: SE5-48H-xxxM (xxx = 345-370, in increment of 5) 84 cells: SE5-xxxM (xxx = 300-325, in increment of 5) 72 cells: SE5-xxxM (xxx = 260-280, in increment of 5) 60 cells: SE5-xxxM (xxx = 215-230, in increment of 5) 48 cells: SE5-xxxM (xxx = 175-185, in increment of 5) 42 cells: SE5-xxxM (xxx = 150-160, in increment of 5) 36 cells: SE5-xxxM (xxx = 130-140, in increment of 5) 30 cells: SE5-xxxM (xxx = 110, 115) 26 cells: SE5-xxxM (xxx = 95, 100) 18 cells: SE5-xxxM (xxx = 65, 70) 16 cells: SE5-60M 14 cells: SE5-50M
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Module types:	**PV Modules with 166mm Mono-crystalline Silicon Half-cut Solar Cells:** 156 cells: SE4-78H-xxxM (xxx = 465-500, in increment of 5) 144 cells: SE4-72H-xxxM (xxx = 430-465, in increment of 5) 132 cells: SE4-66H-xxxM (xxx = 395-425, in increment of 5) 120 cells: SE4-60H-xxxM (xxx = 360-385, in increment of 5) 108 cells: SE4-54H-xxxM (xxx = 325-345, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:
For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.

TÜV NORD CERT GmbH
Certification Body
Consumer Products